


J:\AUTOCAD FILES\AUTOCAD MASTER DWGS\WORKING DWGS\Standard SPEC Dwg\Std-9-Std-RoadTrench.dwg, 11/15/07 11:56:36am, time




**NOTE:**

NATIVE BACKFILL WILL NOT BE ALLOWED IN ROADWAY TRENCHES CONTAINING PUBLIC WATER MAINS. ALL PUBLIC WATER MAINS LOCATED WITHIN AN EXISTING OR PROPOSED ROADWAY (PUBLIC OR PRIVATE) SHALL CONFORM TO THIS STANDARD

**Fair Oaks Water District**

10317 FAIR OAKS BLVD, FAIR OAKS, CA 95628-7187  
 OFFICE (916) 987-5723, FAX (916) 987-0153  
 WEBSITE: WWW.FOWD.COM



**FAIR OAKS  
 WATER DISTRICT**

**TRENCH CROSS SECTION FOR  
 COUNTY IMPROVED AREAS**

**Standard Drawing 9**

APPROVED:  
 M. NISENBOYM  
 DRAWN BY  
 T. EGGAR  
 DRAWING  
**STD-9**  
 REVISED  
 AUG 2007  
 SCALE  
 N/A

**Standard Specifications**