



Policy Number:	6040
Policy Title:	In Line Booster Pumps

1. In general, permanent in-line booster pumps are not allowed within the Fair Oaks Water District. However, a request for the temporary installation of an in-line booster pump will be considered by the General Manager when system deficiencies warrant.
2. The General Manager may approve temporary installation subject to the following:
 - 2.1. Plans shall be submitted to the District showing the location of the proposed in-line booster pump. An analysis shall also be provided to show that the proposed in-line booster pump is necessary and to determine if a negative impact to the surrounding water system may result.
 - 2.2. If installation of an in-line booster pump is approved by the General Manager, the service lateral shall be upgraded to District standards at owner's expense. In addition, the service shall be provided system protection from potential backflow thru the installation of a privately installed and maintained approved RP backflow assembly.
 - 2.3. Installation of an in-line booster pump shall be allowed only until such time the system deficiencies warranting the in-line booster pump the in-line pump, use will be discontinued immediately and removal of the pump may be required.