

**Fair Oaks Water District
Contract Documents
New York Avenue Main Replacement – Phase II**

**ADDENDUM NO. 1
Issued May 22, 2026**

Addendum No. 1 forms a part of the Contract Documents and modifies the original documents dated April 2026.

This Addendum consists of three (3) pages and five (5) attachments:

- Attachment A: Pre-Bid Meeting Sign-In Sheet
- Attachment B: Bid Proposal
- Attachment C: Description of Bid Items
- Attachment D: Designation of Subcontractors
- Attachment E: Project Pre-Qualification Application

Bidder's Note: Bidder shall acknowledge receipt and examination of this addendum on the Bid Proposal as required by the sealed proposal.

Contract Documents – Bid Proposal Change:

- 1) Replace "Bid Proposal" with Attachments B, C, D, and E
- 2) Attachment B was updated to clarify that the Project Pre-Qualification Application is due prior to, or at the time of bid
- 3) Attachment B was updated to include traffic loop restoration as a bid line item
- 4) Attachment C was updated to remove traffic loop restoration from Bid Item No. 25 and 26 and Alternate Bid Item No. A3. Traffic loop restoration is now described separately under Bid Item No. 30
- 5) Attachment C was updated so that Bid Item No. 4 does not exceed 5% of the total project cost instead of 1%
- 6) Attachment D has not been updated. It is included with the revised contract documents for clarity
- 7) Attachment E has not been updated. It is included with the revised contract documents for clarity

Responses to Bidder Questions:

Question #1: Is there an engineer's estimate available?

Response #1: FOWD will not be providing an engineer's estimate.

Question #2: Will a survey be required?

Response #2: The contractor is responsible for conducting a survey in order to determine station numbers, offsets, and points of interest. FOWD will provide the CAD files used for design.

Question #3: Will FOWD provide the number and location of all survey monuments?

Response #3: Based on a visual inspection, there are three survey monuments that may be impacted by this project. Two pins north of the Lemon Street intersection and one monument at the center of the Fair Oaks Boulevard intersection. Where possible, final surface restoration should be performed so as not to disturb the existing survey monuments. The contractor is responsible for final verification and restoration of any disturbed survey monuments per the Contract Documents.

Question #4: Will FOWD perform compaction testing?

Response #4: The contractor is responsible for all compaction testing as described in the Contract Documents.

Question #5: Will FOWD be responsible for the removal of AC pipe?

Response #5: The contractor is responsible for all permitting and safety considerations related to AC pipe removal, storage, and transportation as described in the Contract Documents.

Question #6: Will the sign-in sheet be provided?

Response #6: The sign-in sheet has been included as Attachment A of this addendum.

Question #7: How many valves will be abandoned with this project?

Response #7: Per the retirement chart on the cover sheet of the improvement plans, 12 valves will be abandoned.

Question #8: Will hydrant laterals be tunneled beneath the sidewalk?

Response #8: No, hydrant lateral piping will be open trenched through the sidewalk. Curb, gutter, and sidewalk restoration is included as a bid line item.

Question #9: Is the proposed pipe alignment final?

Response #9: The pipe alignment is final, however, field conditions may warrant that the alignment be modified as needed. Written approval from FOWD is required before any field changes to the design are implemented.

Question #10: Are sewer lateral depths identified on the plans?

Response #10: Yes, all known sewer lateral crossings are identified on the plans.

Question #11: For hydrant abandonments, is removal of the bury assembly required?

Response #11: Removal of the bury assembly is not required. The riser pipe shall be cut 12 – 18” below the surface and capped with concrete. Per the Contract Documents, the hydrant head shall be salvaged and returned to FOWD.

Question #12: Bid Item No. 4 (Erosion and Sediment Control Plan) states that it should not exceed 1% of the total project cost. Can this be increased to 5%?

Response #12: Bid Item No. 4 has been increased to not exceed 5% of the total project cost. Attachment D has been updated accordingly.

Question #13: Will the County allow a full road closure on New York Avenue?

Response #13: The County allowed a full road closure during Phase I of the project between Lemon and Orange Street in 2024. Traffic control restrictions for this project will be defined by the Sacramento County Encroachments Division at the time of permit application. The contractor is responsible for obtaining the Encroachment Permit and for all traffic control as described in the Contract Documents.

Question #14: Is there a waiver from DDW for the proposed water and sewer main separation of less than 10 ft?

Response #14: FOWD has submitted a waiver request to DDW for this project. It is anticipated that approval will be received from DDW prior to project construction.

- END OF ADDENDUM NO. 1 -

PRE-BID SIGN-IN SHEET
 FAIR OAKS WATER DISTRICT
 NEW YORK AVENUE MAIN REPLACEMENT - PHASE II

Name	Company Name	E-Mail Address	Phone #
Blake Chetcuti	Fair Oaks Water District	bchetcuti@fowd.com	(916) 844-3520
Dylan Lee	Fair Oaks Water District	dlee@fowd.com	(916) 844-3514
MIKE WHEELER	WEST VALLEY	mwheeler@wvcc.com	209-983-7286
ROBERT LEWIS	PRO BUILDERS	SEBASTIAN @ SAC PRO BUILDERS.COM	916 225 0373
Taree Cooke	C.E. Cox General Eng.	Cecoteng44@gmail.com	916-995-1959
Mario Cardoza	OEB	Mcardoza2@oeb.org	916-886-3548
TIMMY XIANG	ARB, INC	timmy.xiang@prim.com	925-765-7652
Richard Soracco	Soracco, Inc.	Estimating@Soraccoinc.com	209-267-4030
KIARNA LUM	MCGUIVER'S BEST	sales@mchng.com	916-372-9910
Mike Wunschel	Wunschel & Sons, Inc.	mwunschel@wunschelandsons.com	(530) 622 8675
Daniel Abans	Flowline Contractors	daniel@flowlineinc.com	(805) 680 0246

PRE-BID SIGN-IN SHEET
 FAIR OAKS WATER DISTRICT
 NEW YORK AVENUE MAIN REPLACEMENT – PHASE II

Name	Company Name	E-Mail Address	Phone #
GREEN DAVIS	LAFIBER ENGINEERING, INC	gd@lei-ca.net	(530) 919-1397
Kenny Protopono	Lund Construction	kprotopono@lundconst.com	(530) 899-7186
Harjivan Chatha	Lund Construction	hchatha@lundconst.com	916.825.0611

Attachment B

Bid Proposal

Owner: Fair Oaks Water District

Project Name: New York Avenue Main Replacement – Phase II

Project No: C26TDNYASW2

1. Bids shall be completed on the attached Bid Schedule. All numbered bid items must be completed. Numbers shall be stated in figures and the form shall be signed. Any corrections to entries made on bid forms shall be initialed by the person(s) signing the bid. Before submitting a bid, bidders shall carefully examine the project documents and inspect the site of the work, fully inform themselves as to all existing governmental agency conditions and limitations, and shall include a total cost figure on the bid proposal form.
2. The undersigned, having familiarized themselves with the local conditions affecting the cost of the work, and with the contract documents, for the above named project, do hereby propose to perform everything required to be performed, and to provide and furnish all labor, materials, tools, expendable equipment, and all utility and transportation services necessary to complete work in the above named project, all in accordance with the prepared improvement plans, bidding documents, and specifications.
3. The undersigned agrees, if awarded the contract, to start work within 30 calendar days after issuance of Notice to Proceed, and to complete the same, ready for substantial and unobstructed use by District within 90 calendar days of issuance of Notice to Proceed.
4. The undersigned understands that the works advertised will be awarded to the lowest qualified bidder based on the total base bid. **Prospective bidders must submit a completed Project Pre-Qualification Application by Thursday, May 28, 2026, at 2:00 pm, local time.** Only contractors that have been pre-qualified by FOWD will be eligible to bid on the above-named project.
5. In submitting this bid, it is understood that the right is reserved by FOWD to reject any and all bids or any portion thereof. It is agreed that this bid may not be withdrawn for a period of sixty (60) days from the opening thereof.
6. The undersigned firm/individual holds California State Construction License Number _____ and Worker's Compensation Policy Number _____ issued by _____.
7. The undersigned acknowledges receipt of the Bid Package and Contract Documents for the New York Avenue Main Replacement – Phase II Project consisting of the Invitation to Bid, Bid Proposal, Description of Bid Items, Designation of Subcontractors, Project Pre-Qualification Application, FOWD Standard Specifications, Cal-Trans Specifications for

Trenchless Technology Projects, Improvement Plans, and Example Project Construction Services Contract. The undersigned acknowledges that **addendum number 1** has been received and examined as part of the Bid Package and Contract Documents.

8. The undersigned understands that if awarded the bid, invoices and payments shall be for actual quantities of materials installed at unit cost for each bid item.
9. Bids must be accompanied by a bid security made payable to FOWD in an amount not less than ten percent (10%) of Bidder's maximum bid price. Bid bond will be in the form of a certified check, bank money order, or a Bid Bond (EJCDC No. C-430, 2013 Edition) issued by an approved surety.

Firm Name: _____

Address: _____

City and State: _____

Telephone Number: _____

Email Address: _____

By: _____

Type or Print Name of Person Signing Bid Proposal

Title: _____

By: _____

Signature

Date: _____

Bids are to be returned no later than Thursday May 28, 2026, at 2:00 pm, local time at the Fair Oaks Water District Office. Mark the project name on the sealed bidding envelope and submit bids with attention to Blake Chetcuti.

Return To: Fair Oaks Water District, 10326 Fair Oaks Boulevard, Fair Oaks, CA 95628, Attn: Blake Chetcuti

Bid Proposal Continued ²

Owner: Fair Oaks Water District

Project Name: New York Avenue Main Replacement – Phase II

Project No: C26TDNYASW2

Bid Items

Item	Description	Unit	Quantity	Total Price, \$
1	Mobilization and Demobilization	LS	1	
2	Overhead, Bonding, Insurance, and Permitting	LS	1	
3	Traffic Control	LS	1	
4	Erosion and Sediment Control Plan	LS	1	
5	Installation Only 12” DIP (Class 350) ¹	LF	1,525	
6	Furnish and Install 12” Restrained Gaskets (Field Lok 350 or Approved Equal)	EA	85	
7	Furnish and Install 12” Gate Valves	EA	23	
8	Furnish and Install 12” 45° Elbows	EA	6	
9	Furnish and Install 6” Fire Hydrants	EA	5	
10	Furnish and Install 1” Air and Vacuum Release Valves	EA	2	
11	Furnish and Install 4” Blow Off Assembly and Piping	EA	1	
12	Furnish and Install 1” Water Services. Reconnect to Existing Meter	EA	7	

13	Furnish and Install 1.5" Water Services. Reconnect to Existing Meter	EA	3	
14	Furnish and Install 2" Water Services. Reconnect to Existing Meter	EA	1	
15	Furnish Materials and Install Point of Connection at Sta. 1+25	LS	1	
16	Furnish Materials and Install Point of Connection at Sta. 1+40	LS	1	
17	Furnish Materials and Install Point of Connection at Sta. 4+33	LS	1	
18	Furnish Materials and Install Point of Connection at Sta. 8+11	LS	1	
19	Furnish Materials and Install Point of Connection at Sta. 8+29	LS	1	
20	Furnish Materials and Install Point of Connection at Sta. 14+43	LS	1	
21	Furnish Materials and Install Point of Connection at Sta. 14+51	LS	1	
22	Furnish Materials and Install Point of Connection at Sta. 16+50	LS	1	
23	Disinfection, Flushing, and Pressure Testing	LS	1	
24	Abandon Existing Water Main and Appurtenances	LS	1	
25	Trench Restoration Paving	SF	9,000	
26	Pavement Restoration (Type II Slurry)	SF	29,450	
27	Street Marking Restoration	LS	1	
28	Curb, Gutter, and Sidewalk Restoration	SF	250	
29	Speed Table Restoration	LS	1	

30	Traffic Loop Restoration	EA	2	
31	Restoration of Existing Potholes Outside of Trench Alignment	EA	10	

1. FOWD has pre-purchased 12” DIP (Class 350) and will provide it to the contractor upon bid acceptance.

Total Base Bid Proposal (Items 1 -31) _____

Alternate Bid Items

Item	Description	Unit	Quantity	Total Price, \$
A1	Permitting and Written Plan Approval to Bore 12” DIP Across Fair Oaks Blvd. per Cal Trans Standards	LS	1	
A2	Bore and Install 12” DIP Across Fair Oaks Blvd. per Cal Trans Standards	LF	200	
A3	Pavement Restoration (2” Grind and Overlay)	SF	29,450	
A4	Furnish and Install Invert for Utility Crossing	EA	1	

Alternate Total (Items A1 -A4) _____

2. Bid schedule revised in Addendum #1

Attachment C

Description of Bid Items ²

Bid Item No. 1 – Mobilization and Demobilization (Lump Sum). The work under this bid item includes all contract administration, project mobilization, site development activities, and demobilization as required to conduct and complete the work as identified in the Contract Documents. The total amount shall not exceed five percent (5%) of the Total Base Bid Price as provided in the Bid Schedule.

Bid Item No. 2 – Overhead, Bonding, Insurance, and Permitting (Lump Sum). The work under this bid item includes all overhead, bonding, insurance, and permitting as required to conduct and complete the work as identified in the Contract Documents. The contractor will be responsible for obtaining all permits to comply with local, state, and federal agencies' requirements. This includes, but is not limited to, procuring an Encroachment Permit from the Sacramento County Department of Transportation for any work performed in the public right-of-way.

Bid Item No. 3 – Traffic Control (Lump Sum). The work under this bid item includes the development and implementation of a traffic control plan(s) as required to conduct and complete the work as identified in the Contract Documents. This includes but is not limited to signage, messaging, equipment, materials, supplies, and personnel. The contractor will be responsible for meeting all Sacramento County and Cal Trans specifications and requirements.

Bid Item No. 4 – Erosion and Sediment Control Plan (Lump Sum). The work under this bid item includes the development and implementation of an erosion and sediment control plan(s) as required to conduct and complete the work as identified in the Contract Documents. The contractor will be responsible for meeting all local, state, and federal agencies' requirements. This includes, but is not limited to, erosion and sediment control, water pollution control and protection, and performance of best management practices. The total amount shall not exceed five percent (5%) of the Total Base Bid Price as provided in the Bid Schedule.

Bid Item No. 5 – Installation Only of 12" DIP (Class 350) (Linear Foot). The work under this bid item includes all labor, materials, equipment, and supplies as required to install 12-inch ductile iron pipe (class 350) as shown and specified in the Contract Documents. FOWD has pre-purchased the 12-inch ductile iron pipe and will provide it to the contractor upon bid acceptance. This bid item encompasses installation of the pipe, potholing, excavation, trenching, bedding, backfill, and compaction. The contractor will be responsible for compaction testing in accordance with Sacramento County specifications and requirements.

Bid Item No. 6 – Furnish and Install 12" Restrained Gaskets (Field Lok 350 or Approved Equal) (Each). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install 12-inch restrained gaskets (Field Lok 350 or approved equal) as shown and specified in the Contract Documents. Restrained gaskets will be required for all pipe joints.

Bid Item No. 7 – Furnish and Install 12” Gate Valves (Each). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install 12-inch gate valves as shown and specified in the Contract Documents.

Bid Item No. 8 – Furnish and Install 12” 45° Elbows (Each). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install 12-inch 45° elbows as shown and specified in the Contract Documents.

Bid Item No. 9 – Furnish and Install 6” Fire Hydrants (Each). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install 6-inch fire hydrants and the required hydrant lateral piping and appurtenances as shown and specified in the Contract Documents.

Bid Item No. 10 – Furnish and Install 1” Air and Vacuum Release Valves (Each). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install 1-inch air and vacuum release valves and the required appurtenances as shown and specified in the Contract Documents.

Bid Item No. 11 – Furnish and Install 4” Blow Off Assembly and Piping (Each). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install a 4-inch blow off assembly and the required appurtenances and piping as shown and specified in the Contract Documents.

Bid Item No. 12 – Furnish and Install 1” Water Services. Reconnect to Existing Meter (Each). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install one-inch water services as shown and specified in the Contract Documents. The contractor will be responsible for reconnecting new services to the existing meter setter and replacing the meter box and meter box lid to meet FOWD Standard Specifications.

Bid Item No. 13 – Furnish and Install 1.5” Water Services. Reconnect to Existing Meter (Each). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install one-and-a-half-inch water services as shown and specified in the Contract Documents. The contractor will be responsible for reconnecting new services to the existing meter setter and replacing the meter box and meter box lid to meet FOWD Standard Specifications.

Bid Item No. 14 – Furnish and Install 2” Water Services. Reconnect to Existing Meter (Each). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install two-inch water services as shown and specified in the Contract Documents. The contractor will be responsible for reconnecting new services to the existing meter setter and replacing the meter box and meter box lid to meet FOWD Standard Specifications.

Bid Item No. 15 – Furnish Materials and Install Point of Connection at Sta. 1+25 (Lump Sum). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install the point of connection at station 1+25 as shown and specified in the Contract

Documents. Ductile iron pipe shall be Class 350 with restrained gaskets (Field Lok 350 or approved equal) at all joints. The contractor will be responsible for performing all tie-ins per FOWD Standard Specifications.

Bid Item No. 16 – Furnish Materials and Install Point of Connection at Sta. 1+40 (Lump Sum). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install the point of connection at station 1+40 as shown and specified in the Contract Documents. Ductile iron pipe shall be Class 350 with restrained gaskets (Field Lok 350 or approved equal) at all joints. The contractor will be responsible for performing all tie-ins per FOWD Standard Specifications.

Bid Item No. 17 – Furnish Materials and Install Point of Connection at Sta. 4+33 (Lump Sum). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install the point of connection at station 4+33 as shown and specified in the Contract Documents. Ductile iron pipe shall be Class 350 with restrained gaskets (Field Lok 350 or approved equal) at all joints. The contractor will be responsible for performing all tie-ins per FOWD Standard Specifications.

Bid Item No. 18 – Furnish Materials and Install Point of Connection at Sta. 8+11 (Lump Sum). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install the point of connection at station 8+11 as shown and specified in the Contract Documents. Ductile iron pipe shall be Class 350 with restrained gaskets (Field Lok 350 or approved equal) at all joints. The contractor will be responsible for performing all tie-ins per FOWD Standard Specifications.

Bid Item No. 19 – Furnish Materials and Install Point of Connection at Sta. 8+29 (Lump Sum). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install the point of connection at station 8+29 as shown and specified in the Contract Documents. Ductile iron pipe shall be Class 350 with restrained gaskets (Field Lok 350 or approved equal) at all joints. The contractor will be responsible for performing all tie-ins per FOWD Standard Specifications.

Bid Item No. 20 – Furnish Materials and Install Point of Connection at Sta. 14+43 (Lump Sum). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install the point of connection at station 14+43 as shown and specified in the Contract Documents. Ductile iron pipe shall be Class 350 with restrained gaskets (Field Lok 350 or approved equal) at all joints. The contractor will be responsible for performing all tie-ins per FOWD Standard Specifications.

Bid Item No. 21 – Furnish Materials and Install Point of Connection at Sta. 14+51 (Lump Sum). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install the point of connection at station 14+51 as shown and specified in the Contract Documents. Ductile iron pipe shall be Class 350 with restrained gaskets (Field Lok 350 or

approved equal) at all joints. The contractor will be responsible for performing all tie-ins per FOWD Standard Specifications.

Bid Item No. 22 – Furnish Materials and Install Point of Connection at Sta. 16+50 (Lump Sum). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install the point of connection at station 16+50 as shown and specified in the Contract Documents. Ductile iron pipe shall be Class 350 with restrained gaskets (Field Lok 350 or approved equal) at all joints. The contractor will be responsible for performing all tie-ins per FOWD Standard Specifications.

Bid Item No. 23 – Disinfection, Flushing, and Pressure Testing (Lump Sum). The work under this bid item includes all labor, materials, equipment, and supplies required for disinfection, flushing, pressure testing, and inspection for all pipe, pipe connections, valves, and appurtenances as shown and specified in the Contract Documents. The contractor will be responsible for adhering to FOWD Standard Specifications and AWWA Standards.

Bid Item No. 24 – Abandon Existing Water Main and Appurtenances (Lump Sum). The work under this bid item includes all labor, materials, equipment, and supplies required to abandon and/or remove the existing water mains, water services, valves, air release valves, hydrants, and other appurtenances as shown and specified in the Contract Documents. The contractor will be responsible for adhering to FOWD Standard Specifications and Sacramento County specifications and requirements.

Bid Item No. 25 – Trench Restoration Paving (Square Foot). The work under this bid item includes all labor, materials, equipment, and supplies required to restore asphalt pavement for trenched excavations as shown and specified in the Contract Documents. This includes, but is not limited to, backfill, compaction, compaction testing, paving, utility valve adjustments, and restoration of existing facilities (e.g. survey monuments) as required. The contractor will be responsible for adhering to FOWD Standard Specifications and Sacramento County specifications and requirements.

Bid Item No. 26 – Pavement Restoration (Type II Slurry) (Square Foot). The work under this bid item includes all labor, materials, equipment, and supplies required to apply Type II Slurry seal within the defined paving limits as shown and specified in the Contract Documents. This includes, but is not limited to, backfill, compaction, compaction testing, paving, utility valve adjustments, and restoration of existing facilities (e.g. survey monuments) as required. The contractor will be responsible for adhering to Sacramento County specifications and requirements.

Bid Item No. 27 – Street Marking Restoration (Lump Sum). The work under this bid item includes all labor, materials, equipment, and supplies required to restore street markings as shown and specified in the Contract Documents. The contractor will be responsible for adhering to Sacramento County and Cal Trans specifications and requirements.

Bid Item No. 28 – Curb, Gutter, and Sidewalk Restoration (Square Foot). The work under this bid item includes all labor, materials, equipment, and supplies required to restore the existing curb, gutter, and sidewalk as shown and specified in the Contract Documents. This includes, but is not limited to, the removal, subgrade penetration, compaction, compaction testing, utility adjustments, and/or upgrade of existing facilities as required. The contractor will be responsible for adhering to FOWD Standard Specifications and Sacramento County specifications and requirements.

Bid Item No. 29 – Speed Table Restoration (Lump Sum). The work under this bid item includes all labor, materials, equipment, and supplies required to restore the existing speed table as shown and specified in the Contract Documents. The contractor will be responsible for adhering to FOWD Standard Specifications and Sacramento County specifications and requirements.

Bid Item No. 30 – Traffic Loop Restoration (Each). The work under this bid item includes all labor, materials, equipment, and supplies required to restore the existing traffic loops south of the intersection of Fair Oaks Boulevard and New York Avenue as shown and specified in the Contract Documents. The contractor will be responsible for adhering to FOWD Standard Specifications and Sacramento County specifications and requirements.

Bid Item No. 31 – Restoration of Existing Potholes Outside of Trench Alignment (Each). The work under this bid item includes all labor, materials, equipment, and supplies required to restore existing potholes as shown and specified in the Contract Documents. This includes, but is not limited to, excavation, backfill, compaction, compaction testing, and/or paving as required. The contractor will be responsible for adhering to FOWD Standard Specifications and Sacramento County specifications and requirements.

Alternate Bid Items

Alternate Bid Item No. A1 – Permitting and Written Plan Approval to Bore 12” DIP Across Fair Oaks Blvd. per Cal Trans Standards (Lump Sum). The work under this bid item includes all permitting, data collection, investigation, documentation, and plan approvals as required to conduct and complete a bored-in installation of approximately 200 linear feet of 12-inch ductile iron pipe across the Fair Oaks Boulevard intersection. This bid item serves as an alternative construction method to the open-trench installation shown and specified in the Contract Documents. If approved, Bid Items No. A1 and A2 would replace a portion of Bid Item No. 5 and any other applicable items based on unit pricing. The contractor will be responsible for adhering to Sacramento County and Cal Trans specifications and requirements. A copy of the Cal Trans Guidelines and Specifications for Trenchless Technology Projects is included as Appendix B.

Alternate Bid Item No. A2 – Bore and Install 12” DIP Across Fair Oaks Blvd. per Cal Trans Standards (Linear Foot). The work under this bid item includes all labor, materials, equipment, and supplies as required to conduct and complete a bored-in installation of approximately 200 linear feet of 12-inch ductile iron pipe across the Fair Oaks Boulevard intersection. This bid item serves as an alternative construction method to the open-trench installation shown and specified in

the Contract Documents. If approved, Bid Items No. A1 and A2 would replace a portion of Bid Item No. 5 and any other applicable items based on unit pricing. The contractor will be responsible for adhering to Sacramento County and Cal Trans specifications and requirements. A copy of the Cal Trans Guidelines and Specifications for Trenchless Technology Projects is included as Appendix B.

Alternate Bid Item No. A3 – Pavement Restoration (2” Grind and Overlay) (Square Foot). The work under this bid item includes all labor, materials, equipment, and supplies required to perform a 2-inch grind and overlay of the existing paving within the defined paving limits as shown and specified in the Contract Documents. This bid item serves as an alternative paving method to the Type II Slurry Seal shown and identified in the Contract Documents. If approved, Bid Item No. A3 would replace Bid Item No. 26 and any other applicable items based on unit pricing. This bid item includes, but is not limited to, backfill, compaction, compaction testing, paving, utility valve adjustments, and restoration of existing facilities (e.g. survey monuments) as required. The contractor will be responsible for adhering to Sacramento County specifications and requirements.

Alternate Bid Item No. A4 – Furnish and Install Invert for Utility Crossing (Each). The work under this bid item includes all labor, materials, equipment, and supplies required to furnish and install a 12-inch full invert with 45° elbows as shown and specified in the Contract Documents per FOWD Standard Drawing #11. This bid item may be required for crossings with unknown utilities. If approved, Bid Item No. A4 will replace any other applicable items based on unit pricing. The contractor will be responsible for adhering to FOWD Standard Specifications and Sacramento County specifications and requirements.

2. Description of bid items revised in Addendum #1

Designation of Subcontractors

The following are the names and locations of places of business of all subcontractors who will perform work or labor or render service to the bidder in or about the work, or improvement according to the specifications, in an amount in excess of one-half of one percent (0.5%) of the total bid. Attach an additional sheet, if necessary.

Portion of Work	Subcontractor	Place of Business

Fair Oaks Water District
PROJECT PRE-QUALIFICATION APPLICATION



1. Contractor Information

Legal Business Name:

DBA (if applicable):

Business Address:

Primary Contact Name: _____

Title: _____

Phone Number: _____

Email Address: _____

Emergency Contact (if different):

Name: _____ **Phone:** _____

2. Contractor License Information

California Contractor's License Number: _____

License Classification(s): _____

License Expiration Date: _____

Copy of active license attached

3. Insurance Information

Applicants must meet all Fair Oaks Water District insurance requirements.

Insurance Carrier(s): _____

Policy Types (check all that apply):

General Liability

Workers' Compensation

Fair Oaks Water District
PROJECT PRE-QUALIFICATION APPLICATION



-
- Automobile Liability
 - Other: _____
 - Certificate(s) of Insurance attached
 - Coverage meets FOWD requirements (see attached insurance standards)
-

4. Project Experience (Required)

Provide information for a minimum of three (3) similar projects performed for public agencies within the past five (5) years.

Project 1

Agency Name: _____
Project Description: _____

Project Value: \$ _____
Year Completed: _____
Reference Name: _____
Reference Phone / Email: _____

Project 2

Agency Name: _____
Project Description: _____

Project Value: \$ _____
Year Completed: _____
Reference Name: _____
Reference Phone / Email: _____

Project 3

Agency Name: _____
Project Description: _____

Fair Oaks Water District
PROJECT PRE-QUALIFICATION APPLICATION



Project Value: \$ _____
Year Completed: _____
Reference Name: _____
Reference Phone / Email: _____

(Attach additional pages if necessary)

5. Past Performance With FOWD (If Applicable)

- We have performed work for the Fair Oaks Water District
 We have not performed work for the Fair Oaks Water District

If yes, briefly describe the type of work performed:

6. Safety and Compliance

Has your firm been cited for serious or willful safety violations (OSHA or equivalent) within the past five (5) years?

- Yes No

If yes, please explain and attach supporting documentation:

7. Certification and Acknowledgment

By signing below, the undersigned certifies that:

- All information provided in this application is true, complete, and accurate.
- The applicant agrees to comply with all FOWD standards, policies, and contract requirements.
- The applicant understands that approval is discretionary.

Authorized Representative Name (Printed): _____

Fair Oaks Water District
PROJECT PRE-QUALIFICATION APPLICATION



Title: _____

Signature: _____

Date: _____

8. Submission Instructions

Submit completed application, required attachments, and supporting documentation to:

Fair Oaks Water District
Attn: Contract Administrator
[Mailing Address]
[Email Address]

9. FOR FOWD USE ONLY

Date Received: _____

Reviewed By: _____

Title: _____

Verification Completed:

- License
- Insurance
- References
- Past Performance Review

Recommendation:

Approve Deny Hold / Request Additional Information

Management Decision:

Approved Denied

Decision Date: _____